

ADDENDUM NO. 1 – SAN PATRICIO STREET RECONSTRUCTION – BID CLARIFICATIONS

To: ALL BIDDERS

The following questions and clarifications are provided for all bidders. The bid date and time remain unchanged.

The City of Robstown, City Secretary's office will receive bids for **San Patricio Street (B Street to F Street) Reconstruction Project – CITY OF ROBSTOWN** until 2:00PM on Wednesday, May 11th, 2023, at Robstown City Hall, 101 E Main Ave, Robstown, TX 78380. The bids will be publicly opened and read aloud at 2:30PM on Wednesday, May 11th, 2021, at Robstown City Hall, 101 E Main Ave, Robstown, TX 78380.

Question 1: Note 2 on sheet 2 calls for thermoplastic centerline pavement markings, however there are none existing and no bid item for this. Is this required, and if so, what bid item will it be subsidiary to?

Response: No stripping is required.

Question 2: Is the City of Robstown paying for materials testing or the contractor? The specs reference it both ways. If it is by the contractor, we will need a testing schedule in order to include pricing and a bid item if it is not subsidiary to other bid items.

Response: City will contract directly with the testing lab.

Question 3: There is a bid item for driveway replacement and a bid item for unanticipated driveway removal. For the driveway replacement, I want to clarify that this includes only the new driveway and not the removal of the existing driveway. Because the quantities are the same, I am assuming that the removal will be handled in bid item B07 and the new driveway is handled in bid item B06? Also, request a driveway thickness and reinforcement plan detail to provide accurate pricing.

Response: Driveway removal is bid item B07, and new driveway placement bid item B06. Driveways are to be minimum 6" 3000 psi PCC with No. 4 rebar spaced 6" center.

Question 4: There is a detail for a sidewalk ramp shown on sheet 9. Is this used anywhere?

Response: No sidewalk ramps are currently required.

Question 5: The specifications state that the bidder is required to execute the bid form but there is no signature block, do you just want us to sign and date at the bottom of the page?

Response: Bidder Acknowledgement Form is included and shall be submitted with the Bid Form and the Certification for the Business (follows Table 3 Project History), and other required documents.

Question 6: The specifications require that we submit a Conflict of Interest Questionnaire Form with the bid, but the form is not provided, please send if required.

Response: Forms are included with the Instructions to Bidders.

Question 7: The specifications require that we submit a Disclosure of Interest Form with the bid, but the form is not provided, please send if required.

Response: The standard CIS form is available from the Texas Ethics Commission website under common forms. A sample is attached.

Question 8: The specifications require that we submit a Business Designation Form with the bid, but the form is not provided, please send if required.

Response: Table 1 – ORGANIZATION INFORMATION, is to be used for the Business Designation Form requirement.

Question 9: The specifications require that we submit a Contractors Ethical Behavior Form with the bid, but the form is not provided, please send if required.

Response: See question 7 above, the CIS form and act of bid submission meets the requirements.

Question 10: The specifications require that we submit a Certification Regarding Lobbying Form with the bid, but the form is not provided, please send if required.

Response: Refer to Question 9 above, there are no separate requirements.

Approved:



Jerry J. Shoemaker, P.E.
President/CEO
RH Shackelford, Inc.

5 May 2023
Date

END OF ADDENDUM