



Sec. 3.02.342 Amendments

The following amendments are hereby enacted which exceed the adopted 2011 National Electrical Code, hereafter said to be the electrical code of the city:

- (1) When using fifteen-ampere breakers with no. 14 wire on lighting branch circuits, no more than ten (10) outlets shall be permitted on those circuits.
- (2) When using twenty-ampere breakers with no. 12 wire on general purpose receptacle branch circuits, no more than ten (10) outlets shall be permitted on those, circuits.
- (3) Aluminum wire is prohibited.
- (4) Prohibited for lights and receptacles to share same branch circuit.
- (5) Each commercial building service shall have, as an integral part of the entrance equipment, a main disconnect means located at a readily accessible point immediately adjacent to the meter outside the building or in a separate electrical room, convenient to a person standing on the ground.
- (6) All commercial, assembly and multiple-family structures shall have all wiring installed in conduit.
- (7) On appliance circuits, no more than three (3) outlets shall be permitted.
- (8) Refrigerators, freezers, dishwashers, disposers, microwaves, overhead garage openers and a/c window units shall be install on a dedicated circuit.